

# Certificate of Compliance

**Certificate:** 1081032

**Master Contract:** 160736 (LR 26243)

**Project:** 1081032

**Date Issued:** May 22, 2002

**Issued to:** O'Brien Corporation  
1900 Crystal Industrial Court  
St. Louis, MO 63114  
USA

**Attention:** Mr. Mike Pellegrini, P.E. Engineering Supervisor

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US'*



Issued by  Frank Korcn

Authorized by: Nick Alfano  
Operations Manager



## PRODUCTS

CLASS 2878 02 - HEATERS - Miscellaneous - For Hazardous Locations

CLASS 2878 82 - HEATERS - Miscellaneous - For Hazardous Locations - CERTIFIED TO U.S. STANDARDS

Class I; Div 1, Groups A, B, C, D; Temperature Coded T3

Instrument Heaters, Models CWA\*\*\*D1; Rated 200Watts Max, 277VAC Max

Note \*\*\* are construction variations

Class I; Div 2, Groups A, B, C, D; Temperature Coded T3

Instrument Heaters, Models CWA\*\*\*D2(F); Rated 200Watts Max, 277VAC Max

Note \*\*\* are construction variations

The 'C' and 'US' indicators adjacent to the CSA Mark signify that the product has been evaluated to the applicable CSA and ANSI/UL Standards, for use in Canada and the U.S., respectively. This 'US' indicator includes products eligible to bear the 'NRTL' indicator. NRTL, i.e. National Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognised to perform certification to U.S. Standards.